

Dear Andelshavere,

We have received attached letter from Dansk Sprinkler Teknik in connection with the annual inspection of the sprinkler system:

General information regarding the residential sprinkler system.

The sprinkler system is installed for your personal safety and value protection.

The system works by the heat from a possible fire which triggers the sprinkler (the red glass in the sprinkler = the bulb).



It is **only** the sprinkler(s) that are affected by heat that trigger! - in practice 1 – 2 pcs.

The heat required to trigger the sprinkler is 68 c°

It is only triggered in the room / place where the sprinkler is exposed to heat – nowhere else!

The fire department is automatically called when the sprinklers are triggered in the event of a fire

The sprinklers must not be blocked, e.g. of shelves or things suspended from the ceiling.

Andelsforeningen must approve any installation of walls in apartments.

Note:

The sprinklers cannot withstand mechanical impact and must not be used as hangers - as the system can be triggered if the bulb is broken.

The fire department also comes in the event of a fault!!!!

Dansk Sprinkler Teknik A/S

Emil Neckelmanns Vej 15 G

5220 Odense SØ

